Issue Date: 2015-09-16 Page 1 of 147 Report Reference # 4786910624-5



Test Report issued under the responsibility of:



TEST REPORT IEC 60950-1

Information technology equipment - Safety - Part 1: General requirements

 Report Reference No
 4786910624-5

 Date of issue
 2015-09-16

Total number of pages: 147

CB Testing Laboratory: UL Japan, Inc.

Applicant's name TDK-LAMBDA CORP

NAGAOKA TECHNICAL CENTER

Address R&D DIV

2704-1 SETTAYA-MACHI

NAGAOKA-SHI

NIIGATA 940-1195 JAPAN

Test specification:

Standard: IEC 60950-1:2005 (Second Edition); Am1:2009 + Am2:2013

Test procedure: CB Scheme

Non-standard test method: N/A

Test Report Form No.IEC60950_1FTest Report Form originatorSGS Fimko LtdMaster TRFDated 2014-02

Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer

The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Issue Date: 2015-09-16 Page 2 of 147 Report Reference # 4786910624-5

Test item description: Switching Power Supply

NAGAOKA TECHNICAL CENTER

R&D DIV

2704-1 SETTAYA-MACHI

NAGAOKA-SHI

NIIGATA 940-1195 JAPAN

Model/Type reference RTWx-y (RTW100W series)

RTWx-y# (RTW100W series) RTWx-y* (RTW100W series)

(see "Model Differences" for detail)

Ratings: Input:

AC 100-240 V, 50-60 Hz, 1.1 - 0.55A (3V output type)

AC 100-240 V, 50-60 Hz, 1.5 - 0.75A (others)

Output:

See "Model Difference".

Issue Date: 2015-09-16 Page 3 of 147 Report Reference # 4786910624-5

Testing procedure and testing location:				
[x]	CB Testing Laboratory			
	Testing location / address: UL Japan, Inc. 4383-326 As 0021, Japan	ama-cho, Ise-shi, Mie, 516-		
[]	Associated CB Test Laboratory			
	Testing location / address:			
	Tested by (name + signature): Ayano Matsumoto	A. Matsumoto Tetsuo Iwasaki		
	Approved by (name + signature): Tetsuo lwasaki	Tetsuo Iwasaki		
[]	Testing Procedure: TMP/CTF Stage 1			
	Testing location / address:			
	Tested by (name + signature):			
	Approved by (name + signature):			
[]	Testing Procedure: WMT/CTF Stage 2			
	Testing location / address:			
	Tested by (name + signature):			
	Witnessed by (name + signature):			
	Approved by (name + signature):			
[]	Testing Procedure: SMT/CTF Stage 3 or 4			
	Testing location / address:			
	Tested by (name + signature):			
	Approved by (name + signature):			
	Supervised by (name + signature).:			
[]	Testing Procedure: RMT			
	Testing location / address:			
	Tested by (name + signature):			
	Approved by (name + signature):			
	Supervised by (name + signature).:			

List of Attachments

National Differences (24 pages) Enclosures (57 pages)

Summary Of Testing

Unless otherwise indicated, all tests were conducted at UL Japan, Inc. 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan.

Issue Date: 2015-09-16 Page 4 of 147 Report Reference # 4786910624-5

	Tests performed (name of test and test clause)	Testing location / Comments
	Input: Single-Phase (1.6.2)	
	Capacitance Discharge (2.1.1.7)	
	SELV Reliability Test Including Hazardous Voltage Measurements (2.2.2, 2.2.3, 2.2.4)	
	Protective Bonding I (2.6.3.4, 2.6.1)	
	Humidity (2.9.1, 2.9.2, 5.2.2)	
	Determination of Working Voltage; Working Voltage Measurement (2.10.2)	
	Transformer and Wire /Insulation Electric Strength (2.10.5.13)	
	Heating (4.5.1, 1.4.12, 1.4.13)	
	Ball Pressure (4.5.5, 4.5)	
	Touch Current (Single-Phase; TN/TT System) (5.1, Annex D)	
	Electric Strength (5.2.2)	
	Component Failure (5.3.1, 5.3.4, 5.3.7)	
	Abnormal Operation (5.3.1 - 5.3.9)	
	Transformer Abnormal Operation (5.3.3, 5.3.7b, Annex C.1)	
	Power Supply Output Short-Circuit/Overload (5.3.7)	
Summa	ry of Compliance with National Differences:	
Countrie	s outside the CB Scheme membership may also accept the	is report.
List of co	ountries addressed: CA, DE, DK, EU, FI, GB, SE, SI, US	
The prod	fluct fulfills the requirements of: EN 60950-1:2006 + A1:20	10 + A11:2009 + A12:2011 + A2:2013

Copy of Marking Plate - Refer to Enclosure titled Marking Plate for copy.

Issue Date: 2015-09-16 Page 5 of 147 Report Reference # 4786910624-5

Test item particulars:

Equipment mobility for building-in

Connection to the mains not directly connected to the mains

Operating condition: continuous

Access location restricted access location

Over voltage category (OVC) OVC II

Mains supply tolerance (%) or absolute mains supply

values -10%, +6%

Tested for IT power systems Yes
IT testing, phase-phase voltage (V) 230V
Class of equipment Class I

Considered current rating of protective device as part

of the building installation (A) Considered for 16A

Pollution degree (PD) PD 2

Altitude of operation (m) $\leq 2000 \text{ m}$ Altitude of test laboratory (m) $\leq 1000 \text{ m}$ Mass of equipment (kg) $\leq 1000 \text{ m}$ Approx. 0.3kg

Possible test case verdicts:

Testing:

Date(s) of receipt of test item N/A

Date(s) of Performance of tests 2008-07-01 – 2008-09-19

General remarks:

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a point is used as the decimal separator.

Manufacturer's Declaration per Sub Clause 4.2.5 of IECEE 02:

The application for obtaining a CB Test Certificate includes more than one factory and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided

When differences exist, they shall be identified in the General Product Information section.

Name and address of Factory(ies): TDK-LAMBDA MALAYSIA SDN BHD

PLO33 KAWASAN PERINDUSTRIAN SENAI

Yes

Issue Date: 2015-09-16 Page 6 of 147 Report Reference # 4786910624-5

81400 SENAI MALAYSIA

TDK-LAMBDA MALAYSIA SDN BHD LOT 2 & 3, BATU 9 3/4 KAWASAN PERINDUSTRIAN BANDAR BARU JAYA GADING 26070 KUANTAN MALAYSIA

ALPS LOGISTICS FACILITIES CO LTD 593-1 NISHIOOHASHI TSUKUBA-SHI IBARAKI-KEN 305-0831 JAPAN

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

Product Description

Built- in type switching power supply for use in general office equipment (host equipment is not specified).

Model Differences

The models are essentially the same except for the rating, switching transformer, secondary circuits not affecting safety (see below):

RTWx-y, RTWx-y# or RTWx-y*

- x = 1 to 3 digit number (0-9) which may include a period indicating the Rated Output Voltage within the ranges shown in Table 1.
- y = 1 to 3 digit number (0-9) which may include a period or the letter R and which may be followed by the letter K indicating the Rated Output Current according to the limits shown in Table 1
- # = A, B, D, J, L, M or U indicating various options, option combinations and future unspecified options not affecting safety.
- * = C, E, G, H, N, S, T or V indicating various options, option combinations and future unspecified options not affecting safety.

Cover installation:

Models designated RTWx-y and RTWx-y# are not equipped with a cover. Models designated RTWx-y* are equipped with a cover.

Differences between Output Voltage Types A, B, C, D, E, F and G:

Transformer (T3)

Installation or non-installation of secondary components for adjusting the Output Voltage Ratings:

Issue Date: 2015-09-16 Page 7 of 147 Report Reference # 4786910624-5

Output type₽	Input current∂	Output₽	Transformer T3₽
A₽	0.6 − 0.3A	DC 2.6-4.0V , 12.5A max, 41.25W max	SRW2014PQ-T01V015
B₽	0.7 - 0.35A	DC 4.0-5.8V, 10A max, 50W max₽	SRW2014PQ-T01V015
C₽	0.7 − 0.35A	DC 9.6-13.2V, 4.3A max, 51.6W max	SRW2014PQ-T02V015
D⇔	0.7 - 0.35A	DC 12.0-16.5V, 3.5A max, 52.5W max₽	SRW2014PQ-T10V015
Εø	0.7 − 0.35A	DC 19.2-26.4V, 2.2A max, 52.8W max	SRW2014PQ-T03V014+
F₽	0.7 - 0.35A	DC 22.4-30.8V, 1.8A max, 50.4W max₽	SRW2014PQ-T11V014
G₽	0.7 – 0.35A₽	DC 38.4-52.8V, 1.1A max, 52.8W max	SRW2014PQ-T04V014

Voltage adjustments within the respective voltage ranges of Types A, B, C, D, E, F, G are made by means of voltage adjusting components within the secondary circuit.

Terminal Block:

Suffix "L" models: 3JT1AG092 (L-shaped terminal)

Other models: 3JT0AG092

Examples of the relationship between Type Designation and Power Supply characteristics:

RTW03-12R	RTW48-1R1C	RTW24-2R2L
Output Voltage: DC 3V	Output Voltage: DC 48V	Output Voltage: DC 24V
Output Current: 12A	Output Current: 1.1A	Output Current: 2.2A
Cover: Not equipped	Cover: Equipped	Cover: Not equipped
Terminal: Normal	Terminal: Normal	Terminal: L-shaped

RTW03-12RH RTW12-4R3L

Output Voltage: DC 3V Output Voltage: DC 12V Output Voltage: DC 3V Output Current: 4.3A Output Current: 12A Cover: Equipped Cover: Not equipped Terminal: L-Shaped Terminal: L-shaped Terminal: Normal

RTW03-12B

Additional Information

This report is a reissue of CBTR Ref. No.:12027297 001, CB Test Certificate Ref. No.JPTUV-048722. Based on the previously conducted testing and the review of product technical documentation including photos, schematics, wiring diagrams and similar, has been determined that the product continues to comply with the standard.

Sample Received date is 2003-08-11.
Construction review was conducted on 2003-08-11.

Abbreviations used in the report.

- built-in application: B/I

In this Test Report, CENELEC mark license indicating compliance to EN standard was used to verify component compliance to IEC standard because the standards are technically equivalent.

It was considered that UL Standard has requirements that meet or exceed the relevant IEC requirements.

Technical Considerations

TRF No. : IEC60950_1F This report issued under the responsibility of UL

Issue Date: 2015-09-16 Page 8 of 147 Report Reference # 4786910624-5

- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of: 50°C (models without cover), 40°C (models with cover)
- The product is intended for use on the following power systems: TN, IT (for Norway)
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013 (which includes all European national differences, including those specified in this test report).

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The end-product Electric Strength Test is to be based upon a maximum working voltage of: max working voltage: 300 Vrms, 517 Vpk
- The following secondary output circuits are SELV: All output
- The power supply terminals and/or connectors are: Suitable for factory wiring only
- The maximum investigated branch circuit rating is: 16 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Not been conducted
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C): T2 (Class B), T3 (Class B)
- The following end-product enclosures are required: Fire, Electrical

Abbreviations used in the report:					
- normal condition	N.C.	- single fault condition	.S.F.C		
- operational insulation	OP	- basic insulation	. BI		
- basic insulation between parts of opposite polarity:	ВОР	- supplementary insulation	. SI		
- double insulation	DI	- reinforced insulation	. RI		
Indicate used abbreviations (if any)					