



Test Report issued under the responsibility of:



IEC 60601-1
Medical electrical equipment
Part 1: General requirements for basic safety and essential performance

Report Reference No.: E309264-D1010-1-CB
 Date of issue: 2015-07-17
 Total number of pages: 152

CB Testing Laboratory: UL Japan, Inc.
 Address: 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan

Applicant's name: TDK-LAMBDA CORP
 Address: NAGAOKA TECHNICAL CENTER
 R&D DIV
 2704-1 SETTAYA-MACHI
 NAGAOKA-SHI
 NIIGATA, 940-1195 JAPAN

Test specification:

Standard.....: IEC 60601-1: 2005 + CORR. 1:2006 + CORR. 2:2007 + AM1:2012
 (or IEC 60601-1: 2012 reprint)
 Test procedure: CB Scheme
 Non-standard test method.....: N/A

Test Report Form No.: IEC60601_1J
 Test Report Form Originator: UL(US)
 Master TRF: 2014-07

Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.



If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB testing laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description:	Component Power Supply	
Trade Mark:	Refer to Marking Label enclosure	
Manufacturer:	Same as Applicant	
Model/Type reference:	HWS1500-24/ME, HWS1500-36/ME and HWS1500-48/ME	
Ratings:	Input: All models: 100-240Vac, 20A, 50/60Hz Output: Model HWS1500-24/ME: 24Vdc, 65A (100-180VAC) 70A (180-240VAC) Model HWS1500-36/ME: 36Vdc, 42A (100-180VAC) 46.5A (180-240VAC) Model HWS1500-48/ME: 48Vdc, 32A	
Testing procedure and testing location:		
<input checked="" type="checkbox"/> CB Testing Laboratory:		
Testing location/ address:	UL Japan, Inc. 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan	
<input type="checkbox"/> Associated CB Testing Laboratory:		
Testing location/ address:		
Tested by (name + signature):	Katsuyuki Kusagawa	
Approved by (name + signature):	Tsutomu Abe	
<input type="checkbox"/> Testing procedure: TMP/CTF Stage 1:		
Testing location/ address:		
Tested by (name + signature):		
Approved by (name + signature):		
<input type="checkbox"/> Testing procedure: WMT/CTF Stage 2:		
Testing location/ address:		
Tested by (name + signature):		
Witnessed by (name + signature):		
Approved by (name + signature):		
<input type="checkbox"/> Testing procedure: SMT/CTF Stage 3 or 4:		

Testing location/ address:		
Tested by (name + signature):		
Witnessed by (name + signature):		
Approved by (name + signature):		
Supervised by (name + signature):		

List of Attachments (including a total number of pages in each attachment):

Refer to Appendix A of this report. All attachments are included within this report.

Summary of testing

Tests performed (name of test and test clause):

Testing location:

Refer to the Test List in Appendix B of this report if testing was performed as part of this evaluation.

Summary of compliance with National Differences

List of countries addressed: Austria, USA, Canada, United Kingdom, Sweden

Copy of marking plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

Refer to the enclosure(s) titled Marking Plate in the Enclosures section in Appendix A of this report for a copy.

GENERAL INFORMATION	
Test item particulars:	
Classification of Installation and Use:	Built-in
Device Type:	Component
Intended Use Statement:	To supply regulated power, no patient connection
Mode of Operation:	Continuous
Supply Connection:	None
Accessories and detachable parts included:	None
Other Options Include:	None
Testing	
Date of receipt of test item(s)	2015-05-13
Dates tests performed	2015-06-12 to 2015-06-15
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement.....	Pass (P)
- test object was not evaluated for the requirement	N/E
- test object does not meet the requirement.....	Fail (F)
Abbreviations used in the report:	
- normal condition: N.C.	- single fault condition: S.F.C.
- means of Operator protection: MOOP	- means of Patient protection: MOPP
General remarks:	
"(See Attachment #)" refers to additional information appended to the report.	
"(See appended table)" refers to a table appended to the report.	
The tests results presented in this report relate only to the object tested.	
This report shall not be reproduced except in full without the written approval of the testing laboratory.	
List of test equipment must be kept on file and available for review.	
Additional test data and/or information provided in the attachments to this report.	
Throughout this report a point is used as the decimal separator.	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC60601-1:2012	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	Yes
When differences exist; they shall be identified in the General product information section.	

Name and address of factory (ies): TDK-LAMBDA CORP
 2704-1 SETTAYA-MACHI
 NAGAOKA-SHI
 NIIGATA-KEN, 940-1195 JAPAN

WUXI TDK-LAMBDA ELECTRONICS CO LTD
 NO 6 XING CHUANG ER LU
 WUXI JIANGSU, 214028 CHINA

TDK-LAMBDA MALAYSIA SDN BHD
 PLO33 KAWASAN PERINDUSTRIAN SENAI
 81400, SENAI MALAYSIA

TDK-LAMBDA MALAYSIA SDN BHD
 LOT 2 & 3, BATU 9 3/4
 KAWASAN PERINDUSTRIAN
 BANDAR BARU JAYA GADING
 26070, KUANTAN MALAYSIA

SENDAN ELECTRONICS MFG CO LTD
 1010 HABUSHINI
 NANTO-SHI TOYAMA-KEN 939-1756 JAPAN

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.
 Refer to the Report Modifications page for any modifications made to this report.

Product Description

Products are component power supplies intended to be used as part of Medical Electrical Equipment.
 This AC Input Power Supply provides 2MOOP isolation from Primary to Secondary and 1MOOP isolation from Primary to Earth. It contains the mains transformer with UL Recognized Insulation System.

Model Differences

Models HWS1500-24/ME, HWS1500-36/ME and HWS1500-48/ME are identical, except for output rating, Transformer (T201), Inductor (L401) and some components on secondary circuit.

Additional Information

These products have been previously evaluated to IEC 60601-1: 2005 + CORR. 1 (2006) + CORR. 2 (2007) as detailed in CBTR Ref. No E309264-A55-CB-1 and CB Test Certificate Ref No. US-21008-UL, and evaluated by UL to IEC 60601-1:1988+ A1:1991+ A2:1995 (2nd ed.), UL 60601-1: 1st ed., 2006-04-26 (includes National Differences for USA) and CAN/CSA-C22.2 No. 601.1-M90 (R2005) (includes National Differences for Canada) under Test Report No. E309264-A9 by UL, and also evaluated to IEC 60950-1:2005 under Test Report No. E122103- A37 by UL. All tests conducted per 2nd ed. of IEC 60601-1 and IEC 60950-1 were considered representative of the corresponding tests required by 3rd ed. of IEC 60601-1 as stated under Summary of Testing.

Based on the previously conducted testing and the review of product technical documentation including photos, schematics, wiring diagrams and similar, it has been determined that the product continues to comply with the standard.

All required tests were carried out under the previously investigation.

The following test was conducted in this evaluation as the previously evaluated Test Report might have been insufficient.

- Cl. 5.7: Humidity Preconditioning
- Cl. 8.4.3: Voltage or Charge Limitation
- Cl. 8.7.3 e): Non-frequency-weighted Leakage Current
- Cl. 8.8.3: Dielectric Voltage Withstand

CB Test certificates for components are included in Licenses Enclosure. In accordance with the current rules of CB Scheme, CB Test certificate is effective for 3 years. Recognizing NCB may challenge the CBTC when certificates are more than 3 years.

When submitting this Test Report to other Certification Body, the manufacturer is responsible for providing any additional information that the Body may need in order to issue its Mark, including testing for compliance with the applicable collateral standards.

Technical Considerations

- The product was investigated to the following additional standards:
EN 60601-1:2006/A1:2013, ANSI/AAMI ES60601-1:2005/(R)2012, CSA CAN/CSA-C22.2 NO. 60601-1:14, BS EN 60601:2006 A1, SS-EN 60601-1:2006+A11:2011+A1:2013+AC1:2014+A12:2014
Additional: N/A
- The following additional investigations were conducted: N/A
- The product was not investigated to the following standards or clauses: Biocompatibility (ISO 10993-1), Clause 14, Programmable Electronic Systems, Electromagnetic Compatibility (IEC 60601-1-2)
- The following accessories were investigated for use with the product: N/A
- No Other Considerations.

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

Considerations to the applied parts requirement, to be conducted as end-product

Consideration should be given to measuring the temperature on power electronic components and transformer windings when the power supply is installed in the end-use equipment. The end-use product shall ensure that the power supply is used within its ratings.

The output circuits have not been evaluated for direct patient connection (Type B, BF or CF)

The input/output connectors are not acceptable for field connections, they are only intended for factory wiring inside the end-use product.

The component shall be installed in compliance with the enclosure, mounting, marking, spacing, and separation requirements of the end use application.

The unit provides the following MOOP (means of operator protection): 2 MOOP based upon a working voltage 250Vrms, 420Vpk between input circuit of isolation transformer (T203); 267Vrms, 736Vpk between

input circuit of isolation transformer (T201); 373Vrms, 656Vpk between input circuit of isolation transformer (T700). And the core of the transformer is treated as primary.

Isolation transformer T203 employs a Class A (105 degree C) insulation system.

Isolation transformer T201 employs a Class F (155 degree C) insulation system.

Isolation transformer T700 employs a Class A (105 degree C) insulation system.

Temperature, Leakage Current, Protective Earthing, Dielectric Voltage Withstand, and Interruption of the Power Supply tests should be considered as part of the end product evaluation.

Proper bonding to the end-product main protective earthing termination is required.

The product was tested for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification. See Enclosure "Manuals - (01)" for additional details regarding output derating depends on the product orientation.

The product was submitted and tested for use at the manufacturer's recommended ambient temperature (Tmra) of 50°C.

The products were tested on a 20 A branch circuit. If used on a branch circuit greater than this, additional testing may be necessary.

Additional fusing may be required in the end product to meet the requirement of Cl. 8.11.5, Mains fuses and Over Current Release. The product is only provided and tested with a single fuse.

The end-product evaluation shall ensure that the requirements related to Accompanying Documents, Clause 7.9 are met.

The product is suitable for use in the presence of a flammable anesthetics mixture with air or oxygen or with nitrous oxide: No

The Clearances have additionally been assessed for suitability up to 3000 m elevation.

The risk management requirements of the standard were not addressed.

The investigated Pollution Degree is : 2